Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 402

Water Supply Zone Area: Tetbury and Kingscote

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	12	0	0.01	0.02	0.025	0	MGNH_4
Antimony Total	8	0	0.029	0.07	0.1		UGSB
Arsenic Total	8	0	0.05	0.07	0.09	10	UGAS
Benzo(a)Pyrene	8	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	8	0	0.00137	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00048	0	0.00048		UG_P_L
Benzo(k)fluoranthene	8	0	0.00107	0	0.00107		UG_P_L
Bromate as BrO3	8	0	0.132	0.18	0.387	10	UGBRO
Bromodichloromethane	8	0	0.57	0.78	1.37		UG_P_L
Cadmium Total	8	0	0.006	0.02	0.031		UGCDL
Chromium Total	8	0	0.06	0.14	0.19		UGCRL
Colony Count after 3 days @22C	24	0	0	5.71	130		CFU_1ML
Colour	12	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	1.55	2.25	2.94		UG_P_L
E.Coli Confirmed	24	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	24	0	0.09	0.63	1.03		MG_P_L
Field Total Chlorine	24	0	0.2	0.7	1.27		MG_P_L
First Draw Copper	8	0	14	73.38	165	2,000	UG_P_L
First Draw Nickel	8	0	0.41	1.54	3.92	20	UGNI
First Draw Pb	8	0	0.09	1.33	8.1	10	UGPB
Hydrogen ion (pH)	12	0	7.34	7.45	7.56		PH
Indeno-123-Cd-Pyrene	8	0	0.0022	0	0.0022		UG_P_L
Nitrate as NO3	8	0	2.13	3.13	3.73	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	8	0	0	0	0		MG_P_L
Odour Dilution Number	12	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L
Selenium Total	8	0	0.25	0.32	0.43	10	UGSE
Sodium	8	0	19.7	51.13	167	200	MGNA

Water Quality Summary Date Range: **01 Jul 2025 to 30 Jun 2026**

Water Supply Zone: **402**

Water Supply Zone Area: **Tetbury and Kingscote**

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Taste Dilution Number	**12**	0	**0**	**0**	**0**	0	NONE
Total Aluminium as Al	**12**	0	**8.37**	**10.3**	**11.3**	200	UGAL
Total Coliforms (Indicator)	**24**	0	**0**	**0**	**0**	0	CFU_100ML
Total Iron	**12**	0	**9.28**	**10.84**	**12.6**	200	UGFE
Total Manganese	**12**	0	**1.54**	**1.73**	**1.96**	50	UGMN
Total Oxidised Nitrogen	**8**	0	**2.13**	**3.13**	**3.73**		MG_P_L
Total Trihalomethanes	**8**	0	**3.6**	**5.66**	**8.35**	100	MICROG_L
Tribromomethane	**8**	0	**1.43**	**2.46**	**3.65**		UG_P_L
Trichloromethane	**8**	0	**0.67**	**0.78**	**1.44**		UG_P_L
Turbidity (Treated)	**12**	0	**0.11**	**0.11**	**0.12**	4	NTU