Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 403

Water Supply Zone Area: Sherston, Marshfield and Pucklechurch

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	24	0	0.01	0.02	0.027	0	MGNH_4
Antimony Total	8	0	0.043	0.15	0.37		UGSB
Arsenic Total	8	0	0.07	0.18	0.41	10	UGAS
Benzo(a)Pyrene	8	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	8	0	0.0007	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00048	0	0.00077		UG_P_L
Benzo(k)fluoranthene	8	0	0.00099	0	0.00107		UG_P_L
Bromate as BrO3	8	0	0.132	1.52	5.62	10	UGBRO
Bromodichloromethane	8	0	0.59	5.15	14.2		UG_P_L
Cadmium Total	8	0	0.011	0.02	0.031		UGCDL
Chromium Total	8	0	0.13	0.16	0.19		UGCRL
Colony Count after 3 days @22C	60	0	0	12.22	300		CFU_1ML
Colour	22	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	1.94	7.83	14.51		UG_P_L
E.Coli Confirmed	60	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	60	0	0.05	0.44	1.32		MG_P_L
Field Total Chlorine	60	0	0.11	0.53	1.34		MG_P_L
First Draw Copper	8	0	1.1	61.55	168	2,000	UG_P_L
First Draw Nickel	8	0	0.62	1.29	2.49	20	UGNI
First Draw Pb	8	0	0.09	0.23	0.62	10	UGPB
Hydrogen ion (pH)	26	0	7.25	7.41	7.67		PH
Indeno-123-Cd-Pyrene	8	0	0.00104	0	0.0022		UG_P_L
Nitrate as NO3	8	0	2.62	9.79	21.2	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	8	0	0	0.16	0.42		MG_P_L
Odour Dilution Number	25	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L
Selenium Total	8	0	0.25	0.34	0.43	10	UGSE
Sodium	8	0	38.4	47.25	61.6	200	MGNA

Water Quality Summary Date Range: **01 Jul 2025 to 30 Jun 2026**

Water Supply Zone: **403**

Water Supply Zone Area: **Sherston, Marshfield and Pucklechurch**

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Taste Dilution Number	**25**	0	**0**	**0**	**0**	0	NONE
Total Aluminium as Al	**23**	0	**8.37**	**11.77**	**21.9**	200	UGAL
Total Coliforms (Indicator)	**60**	0	**0**	**0**	**0**	0	CFU_100ML
Total Iron	**24**	0	**9.28**	**15.53**	**40.7**	200	UGFE
Total Manganese	**22**	0	**1.54**	**2**	**6.22**	50	UGMN
Total Oxidised Nitrogen	**8**	0	**2.62**	**9.79**	**21.2**		MG_P_L
Total Trihalomethanes	**8**	0	**5.2**	**21.68**	**48.95**	100	MICROG_L
Tribromomethane	**8**	0	**2.64**	**4.74**	**8.91**		UG_P_L
Trichloromethane	**8**	0	**0.67**	**4.21**	**16.4**		UG_P_L
Turbidity (Treated)	**24**	0	**0.11**	**0.18**	**0.49**	4	NTU