Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 404

Water Supply Zone Area: Filton and Northville

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	52	0	0.01	0.02	0.044	0	MGNH_4
Antimony Total	9	0	0.194	0.33	0.55		UGSB
Arsenic Total	9	0	0.2	0.31	0.7	10	UGAS
Benzo(a)Pyrene	8	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	8	0	0.00137	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00048	0	0.00048		UG_P_L
Benzo(k)fluoranthene	8	0	0.00107	0	0.00107		UG_P_L
Bromate as BrO3	9	0	0.751	2.73	5.62	10	UGBRO
Bromodichloromethane	9	0	3.95	6.93	9.89		UG_P_L
Cadmium Total	9	0	0.006	0.02	0.031		UGCDL
Chromium Total	9	0	0.13	0.16	0.19		UGCRL
Colony Count after 3 days @22C	145	0	0	4.91	300		CFU_1ML
Colour	52	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	9	0	6.26	10.01	15.2		UG_P_L
E.Coli Confirmed	146	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	9	0	0	0	0	0	CFU_100ML
Field Free Chlorine	146	0	0.05	0.52	0.98		MG_P_L
Field Total Chlorine	146	0	0.08	0.64	1.12		MG_P_L
First Draw Copper	9	0	0.82	12.01	37.6	2,000	UG_P_L
First Draw Nickel	9	0	0.84	1.29	3.16	20	UGNI
First Draw Pb	9	0	0.09	0.32	1.18	10	UGPB
Hydrogen ion (pH)	52	0	7.26	7.52	7.73		PH
Indeno-123-Cd-Pyrene	8	0	0.0022	0	0.0022		UG_P_L
Nitrate as NO3	9	0	18.5	23.44	29.2	50	MGNO_3
Nitrite as NO2 (consumer tap)	9	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	9	0	0.37	0.47	0.58		MG_P_L
Odour Dilution Number	53	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L
Selenium Total	9	0	0.25	0.35	0.43	10	UGSE
Sodium	9	0	23.9	45.86	75.7	200	MGNA

Water Quality Summary Date Range: **01 Jul 2025 to 30 Jun 2026**

Water Supply Zone: **404**

Water Supply Zone Area: **Filton and Northville**

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Taste Dilution Number	**53**	0	**0**	**0**	**0**	0	NONE
Total Aluminium as Al	**53**	0	**8.37**	**18.29**	**43.4**	200	UGAL
Total Coliforms (Indicator)	**146**	0	**0**	**0**	**0**	0	CFU_100ML
Total Iron	**52**	0	**9.28**	**12.4**	**67.3**	200	UGFE
Total Manganese	**52**	0	**1.54**	**1.77**	**2.98**	50	UGMN
Total Oxidised Nitrogen	**9**	0	**18.5**	**23.44**	**29.2**		MG_P_L
Total Trihalomethanes	**9**	0	**16.4**	**25.51**	**36.36**	100	MICROG_L
Tribromomethane	**9**	0	**1.4**	**3.57**	**6.13**		UG_P_L
Trichloromethane	**9**	0	**2.52**	**5**	**5.99**		UG_P_L
Turbidity (Treated)	**52**	0	**0.11**	**0.15**	**0.4**	4	NTU