Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 405

Water Supply Zone Area: Bradley Stoke and Winterbourne

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	35	0	0.01	0.02	0.027	0	MGNH_4
Antimony Total	9	0	0.1	0.33	0.5		UGSB
Arsenic Total	9	0	0.12	0.35	0.64	10	UGAS
Benzo(a)Pyrene	10	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	10	0	0.00137	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	10	0	0.00048	0	0.00048		UG_P_L
Benzo(k)fluoranthene	10	0	0.00107	0	0.00107		UG_P_L
Bromate as BrO3	8	0	1.13	2.64	5.84	10	UGBRO
Bromodichloromethane	8	0	1.46	8.05	16.56		UG_P_L
Cadmium Total	9	0	0.006	0.02	0.031		UGCDL
Chromium Total	9	0	0.13	0.15	0.19		UGCRL
Colony Count after 3 days @22C	120	0	0	3.58	285		CFU_1ML
Colour	36	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	2.83	11.23	19.01		UG_P_L
E.Coli Confirmed	120	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	10	0	0	0	0	0	CFU_100ML
Field Free Chlorine	120	0	0.08	0.51	0.92		MG_P_L
Field Total Chlorine	120	0	0.14	0.64	1.15		MG_P_L
First Draw Copper	8	0	0.99	11.03	29	2,000	UG_P_L
First Draw Nickel	8	0	0.87	1.18	1.56	20	UGNI
First Draw Pb	8	0	0.03	0.14	0.58	10	UGPB
Hydrogen ion (pH)	36	0	7.29	7.5	7.71		PH
Indeno-123-Cd-Pyrene	10	0	0.0022	0	0.0022		UG_P_L
Nitrate as NO3	8	0	21.3	24.2	28.9	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	8	0	0.43	0.49	0.58		MG_P_L
Odour Dilution Number	36	0	0	0	0	0	NONE
PAH Total	10	0	0	0	0	0.1	UG_P_L
Selenium Total	9	0	0.25	0.32	0.43	10	UGSE
Sodium	9	0	27.6	48.61	74.7	200	MGNA

Water Quality Summary Date Range: **01 Jul 2025 to 30 Jun 2026**

Water Supply Zone: **405**

Water Supply Zone Area: **Bradley Stoke and Winterbourne**

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Taste Dilution Number	**37**	0	**0**	**0**	**0**	0	NONE
Total Aluminium as Al	**35**	0	**8.37**	**17.13**	**39**	200	UGAL
Total Coliforms (Indicator)	**120**	0	**0**	**0**	**0**	0	CFU_100ML
Total Iron	**36**	0	**9.28**	**15.12**	**52.1**	200	UGFE
Total Manganese	**36**	0	**1.54**	**1.76**	**1.96**	50	UGMN
Total Oxidised Nitrogen	**8**	0	**21.3**	**24.2**	**28.9**		MG_P_L
Total Trihalomethanes	**8**	0	**6.35**	**28.78**	**56.91**	100	MICROG_L
Tribromomethane	**8**	0	**1.34**	**3.94**	**6.86**		UG_P_L
Trichloromethane	**8**	0	**0.72**	**5.56**	**14.48**		UG_P_L
Turbidity (Treated)	**35**	0	**0.11**	**0.14**	**0.28**	4	NTU