Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 406

Water Supply Zone Area: Henbury, Henleaze and Stoke Bishop

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	51	0	0.01	0.02	0.052	0	MGNH_4
Antimony Total	7	0	0.17	0.26	0.45		UGSB
Arsenic Total	7	0	0.32	0.74	1.01	10	UGAS
Benzo(a)Pyrene	7	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	7	0	0.0007	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	7	0	0.00048	0	0.00077		UG_P_L
Benzo(k)fluoranthene	7	0	0.00099	0	0.00107		UG_P_L
Bromate as BrO3	7	0	0.485	2.02	6.03	10	UGBRO
Bromodichloromethane	7	0	5.21	9	13.08		UG_P_L
Cadmium Total	7	0	0.011	0.03	0.059		UGCDL
Chromium Total	7	0	0.12	0.15	0.19		UGCRL
Colony Count after 3 days @22C	156	0	0	9	300		CFU_1ML
Colour	52	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	7	0	5.34	9.77	15.52		UG_P_L
E.Coli Confirmed	157	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	7	0	0	0	0	0	CFU_100ML
Field Free Chlorine	157	0	0.06	0.44	0.93		MG_P_L
Field Total Chlorine	157	0	0.2	0.56	1.03		MG_P_L
First Draw Copper	7	0	1.02	7.52	31.6	2,000	UG_P_L
First Draw Nickel	7	0	0.75	2.47	6.8	20	UGNI
First Draw Pb	7	0	0.09	1.34	2.88	10	UGPB
Hydrogen ion (pH)	51	0	7.41	7.59	7.76		PH
Indeno-123-Cd-Pyrene	7	0	0.00104	0	0.0022		UG_P_L
Nitrate as NO3	7	0	15.3	18.43	21.5	50	MGNO_3
Nitrite as NO2 (consumer tap)	7	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	7	0	0.31	0.37	0.43		MG_P_L
Odour Dilution Number	53	0	0	0	0	0	NONE
PAH Total	7	0	0	0	0	0.1	UG_P_L
Selenium Total	7	0	0.25	0.31	0.43	10	UGSE
Sodium	7	0	23.5	38.07	67.5	200	MGNA

Water Quality Summary Date Range: **01 Jul 2025 to 30 Jun 2026**

Water Supply Zone: **406**

Water Supply Zone Area: **Henbury, Henleaze and Stoke Bishop**

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Taste Dilution Number	**53**	0	**0**	**0**	**0**	0	NONE
Total Aluminium as Al	**52**	0	**11.2**	**17**	**52.5**	200	UGAL
Total Coliforms (Indicator)	**157**	0	**0**	**0**	**0**	0	CFU_100ML
Total Iron	**51**	0	**9.28**	**16.26**	**68.5**	200	UGFE
Total Manganese	**52**	0	**1.54**	**1.77**	**3.41**	50	UGMN
Total Oxidised Nitrogen	**7**	0	**15.3**	**18.43**	**21.5**		MG_P_L
Total Trihalomethanes	**7**	0	**17.46**	**29.92**	**43.97**	100	MICROG_L
Tribromomethane	**7**	0	**1.15**	**2.88**	**6.22**		UG_P_L
Trichloromethane	**7**	0	**5.51**	**8.26**	**12.96**		UG_P_L
Turbidity (Treated)	**52**	0	**0.11**	**0.16**	**0.46**	4	NTU