Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 407

Water Supply Zone Area: Clifton, Horfield, Redland and Kingsdown

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	51	0	0.01	0.02	0.044	0	MGNH_4
Antimony Total	7	0	0.17	0.25	0.41		UGSB
Arsenic Total	7	0	0.19	0.67	0.94	10	UGAS
Benzo(a)Pyrene	7	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	7	0	0.0007	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	7	0	0.00048	0	0.00077		UG_P_L
Benzo(k)fluoranthene	7	0	0.00099	0	0.00107		UG_P_L
Bromate as BrO3	7	0	0.518	2	4.28	10	UGBRO
Bromodichloromethane	7	0	3.01	8.58	15.88		UG_P_L
Cadmium Total	7	0	0.011	0.03	0.054		UGCDL
Chromium Total	7	0	0.13	0.15	0.19		UGCRL
Colony Count after 3 days @22C	178	0	0	4.11	196		CFU_1ML
Colour	51	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	7	0	5.3	9.21	14.02		UG_P_L
E.Coli Confirmed	179	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	7	0	0	0	0	0	CFU_100ML
Field Free Chlorine	179	0	0.1	0.54	1.29		MG_P_L
Field Total Chlorine	179	0	0.22	0.66	1.37		MG_P_L
First Draw Copper	7	0	0.99	15.68	38.5	2,000	UG_P_L
First Draw Nickel	7	0	0.72	0.87	1.18	20	UGNI
First Draw Pb	7	0	0.02	0.9	4.98	10	UGPB
Hydrogen ion (pH)	51	0	7.33	7.6	7.83		PH
Indeno-123-Cd-Pyrene	7	0	0.00104	0	0.0022		UG_P_L
Nitrate as NO3	7	0	14.9	18.06	23.5	50	MGNO_3
Nitrite as NO2 (consumer tap)	7	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	7	0	0.3	0.36	0.47		MG_P_L
Odour Dilution Number	52	1	0	0.1	5	0	NONE
PAH Total	7	0	0	0	0	0.1	UG_P_L
Selenium Total	7	0	0.25	0.31	0.43	10	UGSE
Sodium	7	0	23	35.23	49.1	200	MGNA

Water Quality Summary Date Range: **01 Jul 2025 to 30 Jun 2026**

Water Supply Zone: **407**

Water Supply Zone Area: **Clifton, Horfield, Redland and Kingsdown**

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Taste Dilution Number	**52**	1	**0**	**0.1**	**5**	0	NONE
Total Aluminium as Al	**51**	0	**11.2**	**16.53**	**29.8**	200	UGAL
Total Coliforms (Indicator)	**179**	1	**0**	**0.01**	**1**	0	CFU_100ML
Total Iron	**52**	0	**9.28**	**13.79**	**77.6**	200	UGFE
Total Manganese	**51**	0	**1.54**	**1.88**	**4.25**	50	UGMN
Total Oxidised Nitrogen	**7**	0	**14.9**	**18.06**	**23.5**		MG_P_L
Total Trihalomethanes	**7**	0	**12.03**	**28.28**	**50.91**	100	MICROG_L
Tribromomethane	**7**	0	**1.36**	**2.34**	**3.79**		UG_P_L
Trichloromethane	**7**	0	**2.04**	**8.16**	**17.95**		UG_P_L
Turbidity (Treated)	**51**	0	**0.11**	**0.14**	**0.32**	4	NTU