Report Date:10-Nov-2026

# PUBLIC REGISTER OF INFORMATION

**Water Quality Summary Date Range:** 01 Jul 2025 to 30 Jun 2026

**Water Supply Zone:** 410

**Water Supply Zone Area:** Stapleton, St. George and Coombe

## Prescribed Concentration Values

| Result Description | No. of Samples | No. of Failures | Min | Mean | Max | PCV | Units |
|---|---|---|---|---|---|---|---|
| Ammonium Total | 34 | 0 | 0.01 | 0.02 | 0.025 | 0 | MGNH_4 |
| Antimony Total | 9 | 0 | 0.155 | 0.33 | 0.57 | | UGSB |
| Arsenic Total | 9 | 0 | 0.17 | 0.26 | 0.39 | 10 | UGAS |
| Benzo(a)Pyrene | 9 | 0 | 0.49 | 0.49 | 0.49 | 10 | NG_P_L |
| Benzobfluoranthene | 9 | 0 | 0.0007 | 0 | 0.00137 | | UG_P_L |
| Benzo-Ghi-Perylene | 9 | 0 | 0.00048 | 0 | 0.00077 | | UG_P_L |
| Benzo(k)fluoranthene | 8 | 0 | 0.00099 | 0 | 0.00107 | | UG_P_L |
| Bromate as BrO3 | 9 | 0 | 1.04 | 2.77 | 4.71 | 10 | UGBRO |
| Bromodichloromethane | 9 | 0 | 3.76 | 9.62 | 20.84 | | UG_P_L |
| Cadmium Total | 9 | 0 | 0.006 | 0.03 | 0.119 | | UGCDL |
| Chromium Total | 9 | 0 | 0.13 | 0.15 | 0.19 | | UGCRL |
| Colony Count after 3 days @22C | 83 | 0 | 0 | 11.87 | 300 | | CFU_1ML |
| Colour | 36 | 0 | 3 | 3 | 3 | 20 | MG_PT_CO |
| Dibromochloromethane | 9 | 0 | 6.61 | 11.49 | 17.93 | | UG_P_L |
| E.Coli Confirmed | 83 | 0 | 0 | 0 | 0 | 0 | CFU_100ML |
| Enterococci Confirmed | 9 | 0 | 0 | 0 | 0 | 0 | CFU_100ML |
| Field Free Chlorine | 83 | 0 | 0.05 | 0.39 | 0.94 | | MG_P_L |
| Field Total Chlorine | 83 | 0 | 0.05 | 0.5 | 1.09 | | MG_P_L |
| First Draw Copper | 9 | 0 | 1.11 | 30.37 | 191 | 2,000 | UG_P_L |
| First Draw Nickel | 9 | 0 | 0.41 | 1.18 | 2.21 | 20 | UGNI |
| First Draw Pb | 8 | 0 | 0.02 | 1.11 | 6.01 | 10 | UGPB |
| Hydrogen ion (pH) | 36 | 0 | 7.27 | 7.53 | 7.74 | | PH |
| Indeno-123-Cd-Pyrene | 9 | 0 | 0.00104 | 0 | 0.0022 | | UG_P_L |
| Nitrate as NO3 | 9 | 0 | 17.2 | 21.64 | 27 | 50 | MGNO_3 |
| Nitrite as NO2 (consumer tap) | 9 | 0 | 0.003 | 0.01 | 0.008 | 0.5 | MGNO_2 |
| Nitrogen Formula | 9 | 0 | 0.34 | 0.43 | 0.54 | | MG_P_L |
| Odour Dilution Number | 37 | 0 | 0 | 0 | 0 | 0 | NONE |
| PAH Total | 8 | 0 | 0 | 0 | 0 | 0.1 | UG_P_L |
| Selenium Total | 9 | 0 | 0.25 | 0.34 | 0.43 | 10 | UGSE |
| Sodium | 9 | 0 | 30.3 | 44.87 | 64.2 | 200 | MGNA |

**Water Quality Summary Date Range:** **01 Jul 2025 to 30 Jun 2026**

**Water Supply Zone:** **410**

**Water Supply Zone Area:** **Stapleton, St. George and Coombe**

## Prescribed Concentration Values

| Result Description | No. of Samples | No. of Failures | Min | Mean | Max | PCV | Units |
|---|---|---|---|---|---|---|---|
| Taste Dilution Number | **36** | 0 | **0** | **0** | **0** | 0 | NONE |
| Total Aluminium as Al | **35** | 0 | **8.37** | **15.16** | **39.1** | 200 | UGAL |
| Total Coliforms (Indicator) | **83** | 0 | **0** | **0** | **0** | 0 | CFU_100ML |
| Total Iron | **35** | 0 | **9.28** | **14.74** | **37.4** | 200 | UGFE |
| Total Manganese | **36** | 0 | **1.54** | **1.78** | **2.54** | 50 | UGMN |
| Total Oxidised Nitrogen | **9** | 0 | **17.2** | **21.64** | **27** | | MG_P_L |
| Total Trihalomethanes | **9** | 0 | **15.09** | **32.49** | **63.87** | 100 | MICROG_L |
| Tribromomethane | **9** | 0 | **1.64** | **3.46** | **6.85** | | UG_P_L |
| Trichloromethane | **9** | 0 | **2.76** | **7.91** | **26.41** | | UG_P_L |
| Turbidity (Treated) | **36** | 0 | **0.11** | **0.16** | **0.44** | 4 | NTU |