Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 414

Water Supply Zone Area: Whitchurch, Hengrove, Knowle and Knowle Park

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	76	0	0.01	0.02	0.045	0	MGNH_4
Antimony Total	9	0	0.143	0.27	0.38		UGSB
Arsenic Total	9	0	0.14	0.4	0.77	10	UGAS
Benzo(a)Pyrene	9	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	9	0	0.0007	0	0.00203		UG_P_L
Benzo-Ghi-Perylene	9	0	0.00048	0	0.00077		UG_P_L
Benzo(k)fluoranthene	9	0	0.00099	0	0.00107		UG_P_L
Bromate as BrO3	9	0	1.34	2.71	4.82	10	UGBRO
Bromodichloromethane	9	0	2.23	10.98	17.8		UG_P_L
Cadmium Total	9	0	0.006	0.02	0.031		UGCDL
Chromium Total	9	0	0.11	0.15	0.21		UGCRL
Colony Count after 3 days @22C	205	0	0	16.58	300		CFU_1ML
Colour	76	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	9	0	4.1	11.43	18.72		UG_P_L
E.Coli Confirmed	206	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	10	0	0	0	0	0	CFU_100ML
Field Free Chlorine	207	0	0.05	0.31	0.94		MG_P_L
Field Total Chlorine	207	0	0.1	0.43	1		MG_P_L
First Draw Copper	9	0	1.23	7.04	22.1	2,000	UG_P_L
First Draw Nickel	9	0	0.72	1.57	3.68	20	UGNI
First Draw Pb	9	0	0.09	2.21	5.77	10	UGPB
Hydrogen ion (pH)	76	0	7.17	7.55	7.87		PH
Indeno-123-Cd-Pyrene	9	0	0.00104	0	0.0022		UG_P_L
Nitrate as NO3	9	0	11.8	18.33	24.9	50	MGNO_3
Nitrite as NO2 (consumer tap)	9	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	9	0	0.24	0.37	0.5		MG_P_L
Odour Dilution Number	77	0	0	0	0	0	NONE
PAH Total	9	0	0	0	0.002	0.1	UG_P_L
Selenium Total	9	0	0.25	0.31	0.43	10	UGSE
Sodium	9	0	27.3	41.12	59.1	200	MGNA

Water Quality Summary Date Range: **01 Jul 2025 to 30 Jun 2026**

Water Supply Zone: **414**

Water Supply Zone Area: **Whitchurch, Hengrove, Knowle and Knowle Park**

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Taste Dilution Number	**77**	0	**0**	**0**	**0**	0	NONE
Total Aluminium as Al	**76**	0	**8.37**	**16.29**	**46.5**	200	UGAL
Total Coliforms (Indicator)	**206**	2	**0**	**0.03**	**6**	0	CFU_100ML
Total Iron	**77**	0	**9.28**	**15.49**	**70.1**	200	UGFE
Total Manganese	**75**	0	**1.54**	**1.8**	**3.76**	50	UGMN
Total Oxidised Nitrogen	**9**	0	**11.8**	**18.33**	**24.9**		MG_P_L
Total Trihalomethanes	**9**	0	**9.37**	**36.58**	**55.74**	100	MICROG_L
Tribromomethane	**9**	0	**1.54**	**2.99**	**7.65**		UG_P_L
Trichloromethane	**9**	0	**1.5**	**11.18**	**19.95**		UG_P_L
Turbidity (Treated)	**75**	0	**0.11**	**0.15**	**0.74**	4	NTU