Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 421

Water Supply Zone Area: Wells, Glastonbury, Street and Baltonsborough

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	38	0	0.01	0.02	0.025	0	MGNH_4
Antimony Total	8	0	0.1	0.17	0.234		UGSB
Arsenic Total	8	0	0.83	1.68	3.33	10	UGAS
Benzo(a)Pyrene	8	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	8	0	0.00137	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00048	0	0.00048		UG_P_L
Benzo(k)fluoranthene	8	0	0.00107	0	0.00107		UG_P_L
Bromate as BrO3	8	0	0.132	0.59	1.34	10	UGBRO
Bromodichloromethane	8	0	7.88	11.18	17.93		UG_P_L
Cadmium Total	8	0	0.009	0.02	0.033		UGCDL
Chromium Total	8	0	0.07	0.15	0.19		UGCRL
Colony Count after 3 days @22C	122	0	0	3	83		CFU_1ML
Colour	38	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	4.7	6.98	10.13		UG_P_L
E.Coli Confirmed	122	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	122	0	0.05	0.32	1.05		MG_P_L
Field Total Chlorine	122	0	0.1	0.43	1.07		MG_P_L
First Draw Copper	8	0	2.48	26.21	123	2,000	UG_P_L
First Draw Nickel	8	0	0.41	0.89	2.11	20	UGNI
First Draw Pb	8	0	0.09	0.13	0.22	10	UGPB
Hydrogen ion (pH)	38	0	7.58	7.75	7.98		PH
Indeno-123-Cd-Pyrene	8	0	0.0022	0	0.0022		UG_P_L
Nitrate as NO3	8	0	2.29	8.63	12.7	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	8	0	0.05	0.17	0.25		MG_P_L
Odour Dilution Number	38	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L
Selenium Total	8	0	0.25	0.32	0.43	10	UGSE
Sodium	8	0	8.36	19.16	29.6	200	MGNA

Water Quality Summary Date Range: **01 Jul 2025 to 30 Jun 2026**

Water Supply Zone: **421**

Water Supply Zone Area: **Wells, Glastonbury, Street and Baltonsborough**

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Taste Dilution Number	**38**	0	**0**	**0**	**0**	0	NONE
Total Aluminium as Al	**36**	0	**8.37**	**11.26**	**21.2**	200	UGAL
Total Coliforms (Indicator)	**122**	1	**0**	**0.01**	**1**	0	CFU_100ML
Total Iron	**37**	0	**9.28**	**14.5**	**51.9**	200	UGFE
Total Manganese	**38**	0	**1.54**	**1.76**	**2.02**	50	UGMN
Total Oxidised Nitrogen	**8**	0	**2.29**	**8.63**	**12.7**		MG_P_L
Total Trihalomethanes	**8**	0	**24.93**	**37.8**	**61.28**	100	MICROG_L
Tribromomethane	**8**	0	**0.43**	**1.25**	**1.89**		UG_P_L
Trichloromethane	**8**	0	**8.64**	**18.4**	**31.9**		UG_P_L
Turbidity (Treated)	**38**	0	**0.11**	**0.16**	**0.97**	4	NTU