Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 423

Water Supply Zone Area: Frome, Norton St Philip, Leigh-on-Mendip and Coleford

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	36	0	0.01	0.02	0.073	0	MGNH_4
Antimony Total	8	0	0.143	0.16	0.18		UGSB
Arsenic Total	8	0	0.14	1.01	1.29	10	UGAS
Benzo(a)Pyrene	8	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	8	0	0.00137	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00048	0	0.00048		UG_P_L
Benzo(k)fluoranthene	8	0	0.00107	0	0.00107		UG_P_L
Bromate as BrO3	8	0	0.132	0.13	0.132	10	UGBRO
Bromodichloromethane	8	0	0.98	1.33	1.89		UG_P_L
Cadmium Total	8	0	0.109	0.41	0.691		UGCDL
Chromium Total	8	0	0.12	0.15	0.19		UGCRL
Colony Count after 3 days @22C	107	0	0	4.17	300		CFU_1ML
Colour	36	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	2.31	3.13	4.39		UG_P_L
E.Coli Confirmed	107	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	107	0	0.06	0.39	0.67		MG_P_L
Field Total Chlorine	107	0	0.11	0.45	0.86		MG_P_L
First Draw Copper	8	0	25	119.16	497	2,000	UG_P_L
First Draw Nickel	8	0	2.09	2.64	3.23	20	UGNI
First Draw Pb	8	0	1.02	1.63	2.02	10	UGPB
Hydrogen ion (pH)	35	0	7.23	7.34	7.48		PH
Indeno-123-Cd-Pyrene	8	0	0.0022	0	0.0022		UG_P_L
Nitrate as NO3	8	0	23.5	26.78	31.7	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	8	0	0.47	0.54	0.63		MG_P_L
Odour Dilution Number	34	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L
Selenium Total	8	0	0.25	0.69	1.04	10	UGSE
Sodium	8	0	11.5	12.26	13.3	200	MGNA

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 423

Water Supply Zone Area: Frome, Norton St Philip, Leigh-on-Mendip and Coleford

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Taste Dilution Number	**34**	0	**0**	**0**	**0**	0	NONE
Total Aluminium as Al	**35**	0	**8.37**	**10.28**	**11.3**	200	UGAL
Total Coliforms (Indicator)	**107**	0	**0**	**0**	**0**	0	CFU_100ML
Total Iron	**35**	0	**9.28**	**10.7**	**12.6**	200	UGFE
Total Manganese	**34**	0	**1.54**	**1.77**	**2.41**	50	UGMN
Total Oxidised Nitrogen	**8**	0	**23.5**	**26.78**	**31.7**		MG_P_L
Total Trihalomethanes	**8**	0	**5.32**	**7**	**10.65**	100	MICROG_L
Tribromomethane	**8**	0	**1.88**	**2.44**	**3.67**		UG_P_L
Trichloromethane	**8**	0	**0.67**	**0.69**	**0.79**		UG_P_L
Turbidity (Treated)	**36**	0	**0.11**	**0.13**	**0.25**	4	NTU