Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 424

Water Supply Zone Area: Evercreech, Preistleigh and Lydford

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	12	0	0.01	0.02	0.025	0	MGNH_4
Antimony Total	8	0	0.14	0.16	0.174		UGSB
Arsenic Total	8	0	1.24	1.39	1.85	10	UGAS
Benzo(a)Pyrene	8	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	8	0	0.00137	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00048	0	0.00048		UG_P_L
Benzo(k)fluoranthene	8	0	0.00107	0	0.00107		UG_P_L
Bromate as BrO3	8	0	0.132	0.29	0.607	10	UGBRO
Bromodichloromethane	8	0	1.45	3.79	6.58		UG_P_L
Cadmium Total	8	0	0.522	0.62	0.68		UGCDL
Chromium Total	8	0	0.09	0.16	0.21		UGCRL
Colony Count after 3 days @22C	24	0	0	1.83	14		CFU_1ML
Colour	12	0	3	3	3	20	MG_PT_CO
Conductivity	12	0	492	559.58	610	2,500	US_P_CM
Dibromochloromethane	8	0	3.83	5.74	7.24		UG_P_L
E.Coli Confirmed	24	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	24	0	0.11	0.25	0.38		MG_P_L
Field Total Chlorine	24	0	0.21	0.35	0.58		MG_P_L
First Draw Copper	8	0	25.9	107.58	307	2,000	UG_P_L
First Draw Nickel	8	0	2.9	3.32	3.67	20	UGNI
First Draw Pb	8	0	1.19	1.62	2.18	10	UGPB
Hydrogen ion (pH)	12	0	7.34	7.48	7.56		PH
Indeno-123-Cd-Pyrene	8	0	0.0022	0	0.0022		UG_P_L
Nitrate as NO3	8	0	20.1	23.85	28.5	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	8	0	0.4	0.48	0.57		MG_P_L
Odour Dilution Number	12	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L
Selenium Total	8	0	0.79	0.9	1.09	10	UGSE

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 424

Water Supply Zone Area: Evercreech, Preistleigh and Lydford

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Sodium	**8**	0	**13.2**	**14.7**	**17.7**	200	MGNA
Taste Dilution Number	**13**	0	**0**	**0**	**0**	0	NONE
Total Aluminium as Al	**12**	0	**8.37**	**10.53**	**11.3**	200	UGAL
Total Coliforms (Indicator)	**24**	0	**0**	**0**	**0**	0	CFU_100ML
Total Iron	**12**	1	**9.28**	**137.52**	**1,530**	200	UGFE
Total Manganese	**12**	1	**1.54**	**10.14**	**102**	50	UGMN
Total Oxidised Nitrogen	**8**	0	**20.1**	**23.85**	**28.5**		MG_P_L
Total Trihalomethanes	**8**	0	**8.78**	**16.2**	**24**	100	MICROG_L
Tribromomethane	**8**	0	**3.19**	**3.47**	**3.77**		UG_P_L
Trichloromethane	**8**	0	**0.67**	**3.36**	**6.71**		UG_P_L
Turbidity (Treated)	**12**	0	**0.11**	**0.14**	**0.39**	4	NTU