Report Date:10-Nov-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 428

Water Supply Zone Area: Clevedon

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	25	0	0.01	0.02	0.066	0	MGNH_4
Antimony Total	8	0	0.036	0.1	0.123		UGSB
Arsenic Total	8	0	1.23	1.54	1.72	10	UGAS
Benzo(a)Pyrene	8	0	0.49	0.49	0.49	10	NG_P_L
Benzobfluoranthene	8	0	0.00137	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00048	0	0.00048		UG_P_L
Benzo(k)fluoranthene	8	0	0.00107	0	0.00107		UG_P_L
Bromate as BrO3	8	0	0.134	0.28	0.476	10	UGBRO
Bromodichloromethane	8	0	1.77	5.14	11.16		UG_P_L
Cadmium Total	8	0	0.101	0.11	0.128		UGCDL
Chromium Total	8	0	0.13	0.16	0.19		UGCRL
Colony Count after 3 days @22C	49	0	0	1.2	28		CFU_1ML
Colour	26	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	4.98	6.33	8.15		UG_P_L
E.Coli Confirmed	49	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	49	0	0.15	0.36	0.54		MG_P_L
Field Total Chlorine	49	0	0.22	0.43	0.65		MG_P_L
First Draw Copper	8	0	55.8	142.21	433	2,000	UG_P_L
First Draw Nickel	8	0	0.21	0.79	1.73	20	UGNI
First Draw Pb	8	0	0.09	0.35	1.47	10	UGPB
Hydrogen ion (pH)	25	0	7.24	7.39	7.64		PH
Indeno-123-Cd-Pyrene	8	0	0.0022	0	0.0022		UG_P_L
Nitrate as NO3	8	0	12.2	17.19	19.8	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.003	0.01	0.008	0.5	MGNO_2
Nitrogen Formula	8	0	0.24	0.34	0.4		MG_P_L
Odour Dilution Number	24	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L
Selenium Total	8	0	0.43	0.91	1.19	10	UGSE
Sodium	8	0	21.4	23.05	25.8	200	MGNA

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Water Supply Zone: 428

Water Supply Zone Area: Clevedon

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Taste Dilution Number	**24**	0	**0**	**0**	**0**	0	NONE
Total Aluminium as Al	**24**	0	**8.37**	**10.78**	**19.8**	200	UGAL
Total Coliforms (Indicator)	**49**	0	**0**	**0**	**0**	0	CFU_100ML
Total Iron	**23**	0	**9.28**	**10.88**	**12.6**	200	UGFE
Total Manganese	**25**	0	**1.54**	**1.75**	**1.96**	50	UGMN
Total Oxidised Nitrogen	**8**	0	**12.2**	**17.19**	**19.8**		MG_P_L
Total Trihalomethanes	**8**	0	**12.02**	**21.54**	**47.09**	100	MICROG_L
Tribromomethane	**8**	0	**0.76**	**3.98**	**5.88**		UG_P_L
Trichloromethane	**8**	0	**0.67**	**6.17**	**30.2**		UG_P_L
Turbidity (Treated)	**25**	0	**0.11**	**0.11**	**0.17**	4	NTU