

# PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jan 2025 to 31 Dec 2025

Water Supply Zone: 402

Water Supply Zone Area: Tetbury and Kingscote

Water Supply Zone Population: 7760

## Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	12	0	0.008	0.01	0.025	0	MGNH_4
Antimony Total	9	0	0.01	0.09	0.1		UGSB
Arsenic Total	9	0	0.04	0.07	0.16	10	UGAS
Benzo(a)Pyrene	9	0	0.42	0.45	0.49	10	NG_P_L
Benzobfluoranthene	9	0	0.0007	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	9	0	0.00048	0	0.00077		UG_P_L
Benzo(k)fluoranthene	9	0	0.00099	0	0.00107		UG_P_L
Bromate as BrO3	9	0	0.1	0.18	0.387	10	UGBRO
Bromodichloromethane	9	0	0.57	0.74	1.37		UG_P_L
Cadmium Total	9	0	0.01	0.01	0.011		UGCDL
Chromium Total	9	0	0.04	0.13	0.16		UGCRL
Coliforms Confirmed	5	0	0	0	0		CFU_100ML
Colony Count after 3 days @22C	29	0	0	21.41	300		CFU_1ML
Colour	12	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	9	0	1.55	2.06	3.19		UG_P_L
E.Coli Confirmed	29	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	9	0	0	0	0	0	CFU_100ML
Field Free Chlorine	29	0	0.05	0.53	0.92		MG_P_L
Field Total Chlorine	29	0	0.07	0.6	0.98		MG_P_L
First Draw Copper	9	0	24.4	86.3	237	2,000	UG_P_L
First Draw Nickel	9	0	0.41	1.77	3.92	20	UGNI
First Draw Pb	9	0	0.23	1.54	8.1	10	UGPB
Hydrogen ion (pH)	12	0	7.38	7.52	7.71		PH
Indeno-123-Cd-Pyrene	9	0	0.00104	0	0.0022		UG_P_L
Nitrate as NO3	8	0	2.13	2.33	3.73	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.003	0	0.008	0.5	MGNO_2
Nitrogen Formula	8	0	0	0.01	0.044		MG_P_L
Odour Dilution Number	12	0	0	0	0	0	NONE
PAH Total	9	0	0	0	0	0.1	UG_P_L

**Water Quality Summary Date Range: 01 Jan 2025 to 31 Dec 2025**

**Water Supply Zone: 402**

**Water Supply Zone Area: Tetbury and Kingscote**

**Water Supply Zone Population: 7760**

## **Prescribed Concentration Values**

<b>Result Description</b>	<b>No. of Samples</b>	<b>No. of Failures</b>	<b>Min</b>	<b>Mean</b>	<b>Max</b>	<b>PCV</b>	<b>Units</b>
Selenium Total	9	0	0.08	0.23	0.25	10	UGSE
Sodium	9	0	19.7	41.4	167	200	MGNA
Taste Dilution Number	12	0	0	0	0	0	NONE
Total Aluminium as Al	12	0	5	8.97	14.7	200	UGAL
Total Coliforms (Indicator)	29	0	0	0	0	0	CFU_100ML
Total Iron	12	0	3.72	10.45	12.6	200	UGFE
Total Manganese	12	0	0.6	1.48	1.96	50	UGMN
Total Oxidised Nitrogen	8	0	2.13	2.33	3.73		MG_P_L
Total Trihalomethanes	9	0	3.6	5.07	8.35	100	MICROG_L
Tribromomethane	9	0	1.43	2.03	4.38		UG_P_L
Trichloromethane	9	0	0.67	0.76	1.44		UG_P_L
Turbidity (Treated)	12	0	0.11	0.12	0.16	4	NTU