

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jan 2025 to 31 Dec 2025

Water Supply Zone: 410

Water Supply Zone Area: Stapleton, St. George and Coombe

Water Supply Zone Population: 33450

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	36	0	0.008	0.01	0.025	0	MGNH_4
Antimony Total	9	0	0.12	0.28	0.57		UGSB
Arsenic Total	9	0	0.13	0.34	0.65	10	UGAS
Benzo(a)Pyrene	9	0	0.42	0.46	0.49	10	NG_P_L
Benzobfluoranthene	9	0	0.0007	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	9	0	0.00048	0	0.00077		UG_P_L
Benzo(k)fluoranthene	8	0	0.00099	0	0.00107		UG_P_L
Bromate as BrO3	9	0	0.5	2.39	5.22	10	UGBRO
Bromodichloromethane	9	0	3.52	9.41	20.84		UG_P_L
Cadmium Total	9	0	0.01	0.01	0.016		UGCDL
Chromium Total	9	0	0.12	0.18	0.38		UGCRL
Coliforms Confirmed	9	0	0	0	0		CFU_100ML
Colony Count after 3 days @22C	84	0	0	10.98	300		CFU_1ML
Colour	36	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	9	0	6.61	10.81	16.25		UG_P_L
E.Coli Confirmed	84	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	9	0	0	0	0	0	CFU_100ML
Field Free Chlorine	84	0	0.05	0.43	0.94		MG_P_L
Field Total Chlorine	84	0	0.05	0.53	1.05		MG_P_L
First Draw Copper	9	0	0.98	28.49	191	2,000	UG_P_L
First Draw Nickel	9	0	0.41	1.4	2.21	20	UGNI
First Draw Pb	8	0	0.09	0.61	1.85	10	UGPB
Hydrogen ion (pH)	36	0	7.35	7.54	7.74		PH
Indeno-123-Cd-Pyrene	9	0	0.00104	0	0.0022		UG_P_L
Nitrate as NO3	9	0	13.9	20.37	27	50	MGNO_3
Nitrite as NO2 (consumer tap)	9	0	0.003	0	0.008	0.5	MGNO_2
Nitrogen Formula	9	0	0.279	0.41	0.54		MG_P_L
Odour Dilution Number	36	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L

Water Quality Summary Date Range: 01 Jan 2025 to 31 Dec 2025

Water Supply Zone: 410

Water Supply Zone Area: Stapleton, St. George and Coombe

Water Supply Zone Population: 33450

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Selenium Total	9	0	0.18	0.26	0.34	10	UGSE
Sodium	9	0	24.8	42.58	63.1	200	MGNA
Taste Dilution Number	35	0	0	0	0	0	NONE
Total Aluminium as Al	36	0	5.65	14.05	35.7	200	UGAL
Total Coliforms (Indicator)	84	0	0	0	0	0	CFU_100ML
Total Iron	36	0	5.19	15.75	67.5	200	UGFE
Total Manganese	36	0	0.3	1.82	11.8	50	UGMN
Total Oxidised Nitrogen	9	0	13.9	20.37	27		MG_P_L
Total Trihalomethanes	9	0	14.67	31.67	63.87	100	MICROG_L
Tribromomethane	9	0	1.64	3.25	6.85		UG_P_L
Trichloromethane	9	0	1.77	8.2	26.41		UG_P_L
Turbidity (Treated)	36	0	0.11	0.15	0.44	4	NTU