

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jan 2025 to 31 Dec 2025

Water Supply Zone: 411

Water Supply Zone Area: Eastville, Easton, Netham and St Philips

Water Supply Zone Population: 86175

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	77	0	0.008	0.02	0.121	0	MGNH_4
Antimony Total	8	0	0.12	0.19	0.28		UGSB
Arsenic Total	8	0	0.42	0.98	1.32	10	UGAS
Benzo(a)Pyrene	8	0	0.42	0.46	0.49	10	NG_P_L
Benzobfluoranthene	8	0	0.0007	0	0.00137		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00048	0	0.00077		UG_P_L
Benzo(k)fluoranthene	8	0	0.00099	0	0.00107		UG_P_L
Bromate as BrO3	8	0	0.1	1.21	2.45	10	UGBRO
Bromodichloromethane	8	0	5.72	9.17	14.55		UG_P_L
Cadmium Total	8	0	0.011	0.02	0.039		UGCDL
Chromium Total	8	0	0.09	0.15	0.3		UGCRL
Coliforms Confirmed	23	0	0	0	0		CFU_100ML
Colony Count after 3 days @22C	206	0	0	6.24	300		CFU_1ML
Colour	77	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	5.6	8.41	14.07		UG_P_L
E.Coli Confirmed	208	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	10	0	0	0	0	0	CFU_100ML
Field Free Chlorine	208	0	0.05	0.45	0.9		MG_P_L
Field Total Chlorine	208	0	0.08	0.57	1.04		MG_P_L
First Draw Copper	8	0	0.82	20.44	68.5	2,000	UG_P_L
First Draw Nickel	8	1	0.78	5.38	28	20	UGNI
First Draw Pb	8	0	0.09	0.16	0.27	10	UGPB
Hydrogen ion (pH)	77	0	7.38	7.59	7.87		PH
Indeno-123-Cd-Pyrene	8	0	0.00104	0	0.0022		UG_P_L
Nitrate as NO3	8	0	6.06	11.45	16.8	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.003	0	0.008	0.5	MGNO_2
Nitrogen Formula	8	0	0.12	0.23	0.34		MG_P_L
Odour Dilution Number	77	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L

Water Quality Summary Date Range: 01 Jan 2025 to 31 Dec 2025

Water Supply Zone: 411

Water Supply Zone Area: Eastville, Easton, Netham and St Philips

Water Supply Zone Population: 86175

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Selenium Total	8	0	0.25	0.26	0.34	10	UGSE
Sodium	8	0	13.3	26.55	47.9	200	MGNA
Taste Dilution Number	77	0	0	0	0	0	NONE
Total Aluminium as Al	77	0	5	17.84	67.4	200	UGAL
Total Coliforms (Indicator)	208	3	0	0.02	2	0	CFU_100ML
Total Iron	77	0	3.72	12.16	44.3	200	UGFE
Total Manganese	77	0	0.3	1.57	7.57	50	UGMN
Total Oxidised Nitrogen	8	0	6.06	11.45	16.8		MG_P_L
Total Trihalomethanes	8	0	20.32	30.13	46.1	100	MICROG_L
Tribromomethane	8	0	0.71	1.94	4.35		UG_P_L
Trichloromethane	8	0	5.56	10.61	17.09		UG_P_L
Turbidity (Treated)	77	0	0.11	0.15	0.49	4	NTU