

# PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jan 2025 to 31 Dec 2025

Water Supply Zone: 428

Water Supply Zone Area: Clevedon

Water Supply Zone Population: 16320

## Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	25	0	0.008	0.01	0.025	0	MGNH_4
Antimony Total	8	0	0.03	0.09	0.1		UGSB
Arsenic Total	8	0	1.54	1.69	1.78	10	UGAS
Benzo(a)Pyrene	8	0	0.42	0.46	0.49	10	NG_P_L
Benzobfluoranthene	8	0	0.0007	0	0.00161		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00048	0	0.00077		UG_P_L
Benzo(k)fluoranthene	8	0	0.00099	0	0.00107		UG_P_L
Bromate as BrO3	8	0	0.1	0.23	0.476	10	UGBRO
Bromodichloromethane	8	0	2.05	2.93	5.07		UG_P_L
Cadmium Total	8	0	0.107	0.12	0.128		UGCDL
Chromium Total	8	0	0.13	0.22	0.39		UGCRL
Coliforms Confirmed	5	0	0	0	0		CFU_100ML
Colony Count after 3 days @22C	49	0	0	1.53	28		CFU_1ML
Colour	25	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	5.06	6.43	8.15		UG_P_L
E.Coli Confirmed	49	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	49	0	0.15	0.36	0.54		MG_P_L
Field Total Chlorine	49	0	0.22	0.42	0.65		MG_P_L
First Draw Copper	8	0	52.8	217.71	482	2,000	UG_P_L
First Draw Nickel	8	0	0.29	1.08	1.85	20	UGNI
First Draw Pb	8	0	0.09	0.47	1.47	10	UGPB
Hydrogen ion (pH)	25	0	7.28	7.38	7.46		PH
Indeno-123-Cd-Pyrene	8	0	0.00104	0	0.0022		UG_P_L
Nitrate as NO3	8	0	16.4	18.65	19.4	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.003	0	0.008	0.5	MGNO_2
Nitrogen Formula	8	0	0.33	0.37	0.39		MG_P_L
Odour Dilution Number	25	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0.002	0.1	UG_P_L

**Water Quality Summary Date Range: 01 Jan 2025 to 31 Dec 2025**

**Water Supply Zone: 428**

**Water Supply Zone Area: Clevedon**

**Water Supply Zone Population: 16320**

## **Prescribed Concentration Values**

<b>Result Description</b>	<b>No. of Samples</b>	<b>No. of Failures</b>	<b>Min</b>	<b>Mean</b>	<b>Max</b>	<b>PCV</b>	<b>Units</b>
Selenium Total	8	0	0.87	1.06	1.19	10	UGSE
Sodium	8	0	20.5	22.99	25.8	200	MGNA
Taste Dilution Number	25	0	0	0	0	0	NONE
Total Aluminium as Al	25	0	6.9	9.58	19.8	200	UGAL
Total Coliforms (Indicator)	49	0	0	0	0	0	CFU_100ML
Total Iron	25	0	3.72	10.71	12.6	200	UGFE
Total Manganese	25	0	0.3	1.4	1.96	50	UGMN
Total Oxidised Nitrogen	8	0	16.4	18.65	19.4		MG_P_L
Total Trihalomethanes	8	0	13.26	16.71	21.31	100	MICROG_L
Tribromomethane	8	0	4.92	5.9	7.49		UG_P_L
Trichloromethane	8	0	0.88	1.45	2.93		UG_P_L
Turbidity (Treated)	24	0	0.11	0.12	0.22	4	NTU