

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jan 2025 to 31 Dec 2025

Treatment Works: Shipton M Treated (27410015)

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
1,2 Dichloroethane	8	0	0.16	0.16	0.16	3	UG_P_L
Benzene	8	0	0.06	0.06	0.06	1	UG_P_L
Boron Total	8	0	133	148.38	160	1,000	UG_P_L
Chloride as Cl	8	0	37.3	40.51	43.6	250	MGCL
Clostridia Perfringens Confirmed	24	0	0	0	0	0	CFU_100ML
Coliforms Confirmed	37	0	0	0	0	0	CFU_100ML
Colony Count after 3 days @22C	105	0	0	0.17	3		CFU_1ML
Conductivity	24	0	462	626.38	656	2,500	US_P_CM
Cyanide Total as CN	8	0	1.2	1.23	1.4	50	UGCNL
E.Coli Confirmed	104	1	0	0.01	1	0	CFU_100ML
Field Free Chlorine	104	0	0.63	0.92	1.26		MG_P_L
Field Total Chlorine	104	0	0.66	0.97	1.42		MG_P_L
Fluoride	8	0	380	397.5	430	1,500	UG_P_L
Mercury Total	8	0	0.04	0.05	0.06	1	UGHG
Nitrate as NO3	8	0	2.13	2.53	3.73	50	MGNO_3
Nitrite as NO2	8	0	0.003	0	0.008	0.1	MGNO_2
Nitrogen Formula	8	0	0	0.02	0.044		MG_P_L
Sulphate	8	0	55.6	56.29	57.2	250	MGSO_4
Tetrachloroethene	8	0	0.45	0.45	0.45		UG_P_L
Tetrachloromethane	8	0	0.16	0.16	0.16	3	UG_P_L
Total Chlorethenes	8	0	0.1	0.38	0.85	10	MICROG_L
Total Coliforms (Confirmed)	104	1	0	0.01	1	0	CFU_100ML
Total organic Carbon	8	0	0.7	0.71	0.79		MG_P_L
Total Oxidised Nitrogen	8	0	2.13	2.53	3.73		MG_P_L
Trichloroethene	8	0	0.4	0.4	0.4		UG_P_L
Turbidity - Indicator	104	0	0.11	0.12	0.26	1	NTU