

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Water Supply Zone: 410

Water Supply Zone Area: Stapleton, St. George and Coombe

Water Supply Zone Population: 33313

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	37	0	0.008	0.01	0.025	0	MGNH_4
Antimony Total	8	0	0.12	0.25	0.42		UGSB
Arsenic Total	8	0	0.13	0.38	0.65	10	UGAS
Benzo(a)Pyrene	8	0	0.42	0.42	0.42	10	NG_P_L
Benzobfluoranthene	8	0	0.0007	0	0.0007		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00077	0	0.00077		UG_P_L
Benzo(k)fluoranthene	8	0	0.00099	0	0.00099		UG_P_L
Bromate as BrO3	8	0	0.5	1.85	5.22	10	UGBRO
Bromodichloromethane	8	0	3.52	8.25	14.76		UG_P_L
Cadmium Total	8	0	0.01	0.02	0.03		UGCDL
Chromium Total	8	0	0.12	0.22	0.38		UGCRL
Coliforms Confirmed	9	0	0	0	0		CFU_100ML
Colony Count after 3 days @22C	85	0	0	2.06	41		CFU_1ML
Colour	37	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	6.61	9.57	15.27		UG_P_L
E.Coli Confirmed	85	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	85	0	0.07	0.45	0.77		MG_P_L
Field Total Chlorine	85	0	0.13	0.56	0.9		MG_P_L
First Draw Copper	8	0	0.98	8.68	20	2,000	UG_P_L
First Draw Nickel	8	0	0.85	1.67	2.61	20	UGNI
First Draw Pb	8	0	0.09	1.04	3.06	10	UGPB
Hydrogen ion (pH)	35	0	7.33	7.49	7.68		PH
Indeno-123-Cd-Pyrene	8	0	0.00104	0	0.00104		UG_P_L
Nitrate as NO3	8	0	13.9	18.08	22.7	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.002	0	0.003	0.5	MGNO_2
Nitrogen Formula	8	0	0.279	0.36	0.45		MG_P_L
Odour Dilution Number	35	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Water Supply Zone: 410

Water Supply Zone Area: Stapleton, St. George and Coombe

Water Supply Zone Population: 33313

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Selenium Total	8	0	0.18	0.28	0.32	10	UGSE
Sodium	8	0	24.8	32.83	63.1	200	MGNA
Taste Dilution Number	35	0	0	0	0	0	NONE
Total Aluminium as Al	35	0	5.65	13.04	35.7	200	UGAL
Total Coliforms (Indicator)	85	0	0	0	0	0	CFU_100ML
Total Iron	36	0	3.72	12.47	67.5	200	UGFE
Total Manganese	36	0	0.3	1.26	11.8	50	UGMN
Total Oxidised Nitrogen	8	0	13.9	18.08	22.7		MG_P_L
Total Trihalomethanes	8	0	14.67	28.1	47.99	100	MICROG_L
Tribromomethane	8	0	1.55	2.79	5.31		UG_P_L
Trichloromethane	8	0	1.77	7.49	16.06		UG_P_L
Turbidity (Treated)	36	0	0.07	0.13	0.21	4	NTU