

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Water Supply Zone: 411

Water Supply Zone Area: Eastville, Easton, Netham and St Philips

Water Supply Zone Population: 85599

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	75	0	0.008	0.01	0.053	0	MGNH_4
Antimony Total	8	0	0.1	0.15	0.24		UGSB
Arsenic Total	8	0	0.87	1.15	1.32	10	UGAS
Benzo(a)Pyrene	8	0	0.42	0.42	0.42	10	NG_P_L
Benzobfluoranthene	8	0	0.0007	0	0.0007		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00077	0	0.00077		UG_P_L
Benzo(k)fluoranthene	8	0	0.00099	0	0.00099		UG_P_L
Bromate as BrO3	8	0	0.1	0.45	1	10	UGBRO
Bromodichloromethane	8	0	5.31	8.21	12.78		UG_P_L
Cadmium Total	8	0	0.019	0.03	0.03		UGCDL
Chromium Total	8	0	0.13	0.2	0.32		UGCRL
Coliforms Confirmed	23	0	0	0	0		CFU_100ML
Colony Count after 3 days @22C	205	0	0	3.13	300		CFU_1ML
Colour	77	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	4.23	6.22	7.65		UG_P_L
E.Coli Confirmed	205	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	205	0	0.06	0.44	0.82		MG_P_L
Field Total Chlorine	205	0	0.14	0.57	0.91		MG_P_L
First Draw Copper	8	0	0.82	35.9	198	2,000	UG_P_L
First Draw Nickel	8	0	0.77	1.8	3.33	20	UGNI
First Draw Pb	8	0	0.03	0.27	0.74	10	UGPB
Hydrogen ion (pH)	76	0	7.41	7.58	7.73		PH
Indeno-123-Cd-Pyrene	8	0	0.00104	0	0.00104		UG_P_L
Nitrate as NO3	8	0	4.32	8.49	15.3	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.002	0	0.003	0.5	MGNO_2
Nitrogen Formula	8	0	0.087	0.17	0.307		MG_P_L
Odour Dilution Number	74	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Water Supply Zone: 411

Water Supply Zone Area: Eastville, Easton, Netham and St Philips

Water Supply Zone Population: 85599

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Selenium Total	8	0	0.25	0.29	0.32	10	UGSE
Sodium	8	0	12.7	17.53	25.6	200	MGNA
Taste Dilution Number	74	0	0	0	0	0	NONE
Total Aluminium as Al	76	0	5	22.34	198	200	UGAL
Total Coliforms (Indicator)	205	0	0	0	0	0	CFU_100ML
Total Iron	77	0	3.72	7.68	25.1	200	UGFE
Total Manganese	75	0	0.3	1.11	7.57	50	UGMN
Total Oxidised Nitrogen	8	0	4.32	8.49	15.3		MG_P_L
Total Trihalomethanes	8	0	17.67	27.09	40.2	100	MICROG_L
Tribromomethane	8	0	0.46	1.05	1.88		UG_P_L
Trichloromethane	8	0	5.56	11.61	19.02		UG_P_L
Turbidity (Treated)	74	0	0.07	0.16	0.43	4	NTU