

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Water Supply Zone: 412

Water Supply Zone Area: Kingswood, Fishponds and Mangotsfield

Water Supply Zone Population: 58712

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	51	0	0.008	0.01	0.037	0	MGNH_4
Antimony Total	8	0	0.12	0.22	0.38		UGSB
Arsenic Total	8	0	0.14	0.31	0.44	10	UGAS
Benzo(a)Pyrene	8	0	0.42	0.42	0.42	10	NG_P_L
Benzobfluoranthene	8	0	0.0007	0	0.0007		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00077	0	0.00077		UG_P_L
Benzo(k)fluoranthene	8	0	0.00099	0	0.00099		UG_P_L
Bromate as BrO3	8	0	0.3	1.34	2.34	10	UGBRO
Bromodichloromethane	8	0	1.6	6.84	12.38		UG_P_L
Cadmium Total	8	0	0.01	0.02	0.03		UGCDL
Chromium Total	8	0	0.14	0.24	0.37		UGCRL
Coliforms Confirmed	16	0	0	0	0		CFU_100ML
Colony Count after 3 days @22C	142	0	0	7.15	300		CFU_1ML
Colour	51	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	3.29	8.34	12.26		UG_P_L
E.Coli Confirmed	142	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	142	0	0.08	0.53	1.11		MG_P_L
Field Total Chlorine	142	0	0.05	0.63	1.36		MG_P_L
First Draw Copper	8	0	1.18	127.62	856	2,000	UG_P_L
First Draw Nickel	8	1	0.49	7.7	49.4	20	UGNI
First Draw Pb	8	0	0.06	0.54	2.07	10	UGPB
Hydrogen ion (pH)	51	0	7.28	7.49	7.73		PH
Indeno-123-Cd-Pyrene	8	0	0.00104	0	0.00104		UG_P_L
Nitrate as NO3	8	0	17.04	18.77	22.24	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.002	0	0.003	0.5	MGNO_2
Nitrogen Formula	8	0	0.341	0.38	0.445		MG_P_L
Odour Dilution Number	51	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0	0.1	UG_P_L

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Water Supply Zone: 412

Water Supply Zone Area: Kingswood, Fishponds and Mangotsfield

Water Supply Zone Population: 58712

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Selenium Total	8	0	0.25	0.28	0.32	10	UGSE
Sodium	8	0	23.2	32.89	55.6	200	MGNA
Taste Dilution Number	51	0	0	0	0	0	NONE
Total Aluminium as Al	51	0	5	12.47	44.7	200	UGAL
Total Coliforms (Indicator)	142	0	0	0	0	0	CFU_100ML
Total Iron	51	0	3.72	8.37	33.4	200	UGFE
Total Manganese	51	0	0.3	1.15	7.65	50	UGMN
Total Oxidised Nitrogen	8	0	17.04	18.77	22.24		MG_P_L
Total Trihalomethanes	8	0	7.41	23.81	39.69	100	MICROG_L
Tribromomethane	8	0	1.48	2.75	4.29		UG_P_L
Trichloromethane	8	0	1.05	5.89	12.38		UG_P_L
Turbidity (Treated)	51	0	0.07	0.15	0.38	4	NTU