

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Water Supply Zone: 428

Water Supply Zone Area: Clevedon

Water Supply Zone Population: 16272

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Ammonium Total	24	0	0.008	0.01	0.017	0	MGNH_4
Antimony Total	8	0	0.02	0.07	0.1		UGSB
Arsenic Total	8	0	1.7	1.76	1.81	10	UGAS
Benzo(a)Pyrene	8	0	0.42	0.42	0.42	10	NG_P_L
Benzobfluoranthene	8	0	0.0007	0	0.00161		UG_P_L
Benzo-Ghi-Perylene	8	0	0.00077	0	0.00077		UG_P_L
Benzo(k)fluoranthene	8	0	0.00099	0	0.00099		UG_P_L
Bromate as BrO3	8	0	0.1	0.16	0.3	10	UGBRO
Bromodichloromethane	8	0	1.99	2.58	2.94		UG_P_L
Cadmium Total	8	0	0.107	0.12	0.13		UGCDL
Chromium Total	8	0	0.1	0.25	0.39		UGCRL
Coliforms Confirmed	5	0	0	0	0		CFU_100ML
Colony Count after 3 days @22C	48	0	0	1.31	24		CFU_1ML
Colour	24	0	3	3	3	20	MG_PT_CO
Dibromochloromethane	8	0	5.44	6.19	7.45		UG_P_L
E.Coli Confirmed	48	0	0	0	0	0	CFU_100ML
Enterococci Confirmed	8	0	0	0	0	0	CFU_100ML
Field Free Chlorine	48	0	0.15	0.32	0.53		MG_P_L
Field Total Chlorine	48	0	0.21	0.38	0.6		MG_P_L
First Draw Copper	8	0	52.8	225.68	482	2,000	UG_P_L
First Draw Nickel	8	0	0.69	3.38	15.6	20	UGNI
First Draw Pb	8	0	0.27	0.63	1.26	10	UGPB
Hydrogen ion (pH)	24	0	7.27	7.38	7.53		PH
Indeno-123-Cd-Pyrene	8	0	0.00104	0	0.00104		UG_P_L
Nitrate as NO3	8	0	18.7	19.29	20.26	50	MGNO_3
Nitrite as NO2 (consumer tap)	8	0	0.002	0	0.003	0.5	MGNO_2
Nitrogen Formula	8	0	0.375	0.39	0.406		MG_P_L
Odour Dilution Number	25	0	0	0	0	0	NONE
PAH Total	8	0	0	0	0.002	0.1	UG_P_L

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Water Supply Zone: 428

Water Supply Zone Area: Clevedon

Water Supply Zone Population: 16272

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Selenium Total	8	0	0.99	1.1	1.25	10	UGSE
Sodium	8	0	20.4	21.71	23.5	200	MGNA
Taste Dilution Number	25	0	0	0	0	0	NONE
Total Aluminium as Al	24	0	5	8.7	17.4	200	UGAL
Total Coliforms (Indicator)	48	0	0	0	0	0	CFU_100ML
Total Iron	25	0	3.72	7.44	13.2	200	UGFE
Total Manganese	25	0	0.3	0.84	1.54	50	UGMN
Total Oxidised Nitrogen	8	0	18.7	19.29	20.26		MG_P_L
Total Trihalomethanes	8	0	13.53	16.21	18.87	100	MICROG_L
Tribromomethane	8	0	5.6	6.27	7.49		UG_P_L
Trichloromethane	8	0	0.67	1.26	2.68		UG_P_L
Turbidity (Treated)	24	0	0.07	0.12	0.22	4	NTU