

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Treatment Works: Littleton Treated (27410010)

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
1,2 Dichloroethane	10	0	<0.16	0.16	0.16	3	UG_P_L
2,4-Dichlorophenoxyacetic acid	10	0	<0.010	0.01	0.01	0.1	UG_P_L
Benzene	10	0	<0.06	0.06	0.06	1	UG_P_L
Boron Total	10	0	38.0	51.64	72.1	1,000	UG_P_L
Carbetamide	10	0	<0.009	0.01	0.01	0.1	UG_P_L
Chloride as Cl	10	0	25.8	30.83	55.2	250	MGCL
Chlormequat Cation	10	0	<0.008	0.01	0.01		UG_P_L
Clopyralid	10	0	<0.012	0.01	0.01	0.1	UG_P_L
Clostridia Perfringens Confirmed	52	0	0	0	0	0	CFU_100ML
Coliforms Confirmed	183	0	0	0	0	0	CFU_100ML
Colony Count after 3 days @22C	183	0	0	0.38	46		CFU_1ML
Conductivity	50	0	335	551.8	763	2,500	US_P_CM
Cyanide Total as CN	10	0	<1.2	1.22	1.4	50	UGCNL
E.Coli Confirmed	183	0	0	0	0	0	CFU_100ML
Field Free Chlorine	183	0	0.72	1.01	1.4		MG_P_L
Field Total Chlorine	183	0	0.75	1.08	1.44		MG_P_L
Flufenacet	10	0	<0.008	0.01	0.01	0.1	UG_P_L
Fluoride	10	0	120.0	137	180	1,500	UG_P_L
Fluroxypyr	8	0	<0.011	0.01	0.01	0.1	UG_P_L
Glyphosate	10	0	<0.005	0.01	0.01	0.1	UG_P_L
MCPA	10	0	<0.008	0.01	0.01	0.1	UG_P_L
MCPP	10	0	<0.010	0.01	0.01	0.1	UG_P_L
Mercury Total	10	0	<0.04	0.05	0.06	1	UGHG
Metaldehyde	2	0	<0.006	0.01	0.01	0.1	UG_P_L
Metazachlor	8	0	<0.005	0.01	0.01		UG_P_L
Nitrate as NO3	10	0	14.99	18.46	22.3	50	MGNO_3
Nitrite as NO2	10	0	<0.002	0	0	0.1	MGNO_2
Nitrogen Formula	10	0	0.300	0.37	0.45		MG_P_L
Propyzamide	10	0	<0.009	0.01	0.01	0.1	UG_P_L
Prosulfocarb	2	0	<0.006	0.01	0.01	0.1	UG_P_L
Quinmerac	10	0	<0.006	0.01	0.01	0.1	UG_P_L

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Treatment Works: Littleton Treated (27410010)

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Sulphate	10	0	47.0	60.85	93	250	MGSO_4
Tebuconazole	10	0	<0.006	0.01	0.01	0.1	UG_P_L
Tetrachloroethene	10	0	<0.45	0.45	0.45		UG_P_L
Tetrachloromethane	10	0	<0.16	0.16	0.16	3	UG_P_L
Total Chlorethenes	10	0	0.85	0.85	0.85	10	MICROG_L
Total Coliforms (Confirmed)	183	0	0	0	0	0	CFU_100ML
Total organic Carbon	10	0	0.90	1.47	2.38		MG_P_L
Total Oxidised Nitrogen	10	0	14.99	18.46	22.3		MG_P_L
Total Pesticides	10	0	0	0	0	0.5	UG_P_L
Trichloroethene	10	0	<0.40	0.4	0.4		UG_P_L
Triclopyr	10	0	<0.019	0.02	0.02	0.1	UG_P_L
Turbidity - Indicator	183	0	<0.07	0.15	0.4	1	NTU