

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2024 to 30 Jun 2025

Treatment Works: Tetbury Treated

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
1,2 Dichloroethane	9	0	<0.16	0.16	0.16	3	UG_P_L
Benzene	9	0	<0.06	0.06	0.06	1	UG_P_L
Boron Total	9	0	73.2	81.04	88.1	1,000	UG_P_L
Chloride as Cl	9	0	22.6	23.62	24.5	250	MGCL
Clostridia Perfringens Confirmed	8	0	0	0	0	0	CFU_100ML
Coliforms Confirmed	28	0	0	0	0	0	CFU_100ML
Colony Count after 3 days @22C	35	0	0	0.2	1		CFU_1ML
Conductivity	8	0	541	570.88	584	2,500	US_P_CM
Cyanide Total as CN	10	0	<1.2	1.2	1.2	50	UGCNL
E.Coli Confirmed	35	0	0	0	0	0	CFU_100ML
Field Free Chlorine	35	0	0.35	0.57	0.72		MG_P_L
Field Total Chlorine	35	0	0.4	0.62	0.8		MG_P_L
Fluoride	9	0	190.0	227.78	250	1,500	UG_P_L
Mercury Total	9	0	<0.04	0.05	0.06	1	UGHG
Nitrate as NO3	9	0	<2.13	2.13	2.13	50	MGNO_3
Nitrite as NO2	9	0	<0.003	0	0	0.1	MGNO_2
Nitrogen Formula	9	0	0.000	0.04	0.04		MG_P_L
Sulphate	9	0	59.9	60.91	63.9	250	MGSO_4
Tetrachloroethene	9	0	<0.45	0.45	0.45		UG_P_L
Tetrachloromethane	9	0	<0.16	0.16	0.16	3	UG_P_L
Total Chlorethenes	9	0	<0.10	0.77	0.85	10	MICROG_L
Total Coliforms (Confirmed)	35	0	0	0	0	0	CFU_100ML
Total organic Carbon	9	0	<0.70	0.7	0.7		MG_P_L
Total Oxidised Nitrogen	9	0	<2.13	2.13	2.13		MG_P_L
Trichloroethene	9	0	<0.40	0.4	0.4		UG_P_L
Turbidity - Indicator	35	0	<0.11	0.16	0.46	1	NTU