Report Date:05-Aug-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Treatment Works: Littleton Treated (27410010)

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
1,2 Dichloroethane	10	0	0.16	0.16	0.16	3	UG_P_L
2,4-Dichlorophenoxyacetic acid	13	0	0.01	0.01	0.01	0.1	UG_P_L
Aldrin	6	0	0.008	0.01	0.008		UG_P_L
Azoxystrobin	7	0	0.006	0.01	0.006		UG_P_L
Benzene	10	0	0.04	0.06	0.06	1	UG_P_L
Boron Total	10	0	39.8	59.03	89.4	1,000	UG_P_L
Carbetamide	13	0	0.009	0.01	0.009	0.1	UG_P_L
Chloride as Cl	10	0	26.5	45.36	76	250	MGCL
Chlormequat Cation	13	0	0.008	0.01	0.008		UG_P_L
cis-Heptachlor Epoxide	6	0	0.007	0.01	0.007		UG_P_L
Clopyralid	13	0	0.012	0.01	0.024	0.1	UG_P_L
Clostridia Perfringens Confirmed	102	0	0	0	0	0	CFU_100ML
Colony Count after 3 days @22C	325	0	0	0.2	5		CFU_1ML
Conductivity	101	0	384	583.68	778	2,500	US_P_CM
Cyanide Total as CN	10	0	1.2	1.2	1.2	50	UGCNL
Desthioprothioconazole	7	0	0.007	0.01	0.007		UG_P_L
Dieldrin	7	0	0.009	0.01	0.009		UG_P_L
E.Coli Confirmed	328	0	0	0	0	0	CFU_100ML
Field Free Chlorine	330	0	0.34	0.95	1.31		MG_P_L
Field Total Chlorine	330	0	0.51	1.04	1.39		MG_P_L
Flufenacet	13	0	0.008	0.01	0.008	0.1	UG_P_L
Fluoride	10	0	80	134	180	1,500	UG_P_L
Glyphosate	13	0	0.005	0.01	0.005	0.1	UG_P_L
Heptachlor	4	0	0.005	0.01	0.005		UG_P_L
MCPA	13	0	0.008	0.01	0.008	0.1	UG_P_L
MCPP	13	0	0.01	0.01	0.01	0.1	UG_P_L
Mercury Total	10	0	0.04	0.04	0.06	1	UGHG
Metaldehyde	13	0	0.006	0.01	0.006	0.1	UG_P_L
Nitrate as NO3	8	0	17	23.44	30.5	50	MGNO_3
Nitrite as NO2	8	0	0.003	0.01	0.008	0.1	MGNO_2
Nitrogen Formula	8	0	0.34	0.47	0.61		MG_P_L

Water Quality Summary Date Range: **01 Jul 2025 to 30 Jun 2026**

Treatment Works: **Littleton Treated** **(27410010)**

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Propyzamide	**13**	0	**0.009**	**0.01**	**0.009**	0.1	UG_P_L
Prosulfocarb	**13**	0	**0.006**	**0.01**	**0.006**	0.1	UG_P_L
Quinmerac	**6**	0	**0.006**	**0.01**	**0.006**	0.1	UG_P_L
Sulphate	**10**	0	**55.5**	**87.99**	**134**	250	MGSO_4
Tebuconazole	**13**	0	**0.006**	**0.01**	**0.006**	0.1	UG_P_L
Tetrachloroethene	**10**	0	**0.08**	**0.38**	**0.45**		UG_P_L
Tetrachloromethane	**10**	0	**0.07**	**0.14**	**0.16**	3	UG_P_L
Total Chlorethenes	**10**	0	**0.1**	**0.1**	**0.1**	10	MICROG_L
Total Coliforms (Confirmed)	**328**	0	**0**	**0**	**0**	0	CFU_100ML
Total Heptachlor Epoxide	**6**	0	**0**	**0**	**0**		UG_P_L
Total organic Carbon	**10**	0	**0.96**	**1.66**	**2.51**		MG_P_L
Total Oxidised Nitrogen	**8**	0	**17**	**23.44**	**30.5**		MG_P_L
Total Pesticides	**13**	0	**0**	**0**	**0**	0.5	UG_P_L
trans-Heptachlor epoxide	**6**	0	**0.007**	**0.01**	**0.007**		UG_P_L
Trichloroethene	**10**	0	**0.2**	**0.36**	**0.4**		UG_P_L
Triclopyr	**13**	0	**0.019**	**0.02**	**0.019**	0.1	UG_P_L
Turbidity - Indicator	**330**	0	**0.11**	**0.14**	**0.48**	1	NTU