Report Date:05-Aug-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Treatment Works: Oldford Treated

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
1,2 Dichloroethane	**10**	0	**0.16**	**0.16**	**0.16**	3	UG_P_L
Aldrin	**5**	0	**0.008**	**0.01**	**0.008**		UG_P_L
Benzene	**10**	0	**0.04**	**0.06**	**0.06**	1	UG_P_L
Boron Total	**10**	0	**45.7**	**47.5**	**49.8**	1,000	UG_P_L
Chloride as Cl	**10**	0	**17.3**	**19.1**	**21.1**	250	MGCL
cis-Heptachlor Epoxide	**5**	0	**0.007**	**0.01**	**0.007**		UG_P_L
Clostridia Perfringens Confirmed	**52**	0	**0**	**0**	**0**	0	CFU_100ML
Colony Count after 3 days @22C	**360**	0	**0**	**2.05**	**300**		CFU_1ML
Conductivity	**53**	0	**541**	**591.36**	**614**	2,500	US_P_CM
Cyanide Total as CN	**10**	0	**1.2**	**1.2**	**1.2**	50	UGCNL
Dieldrin	**5**	0	**0.009**	**0.01**	**0.009**		UG_P_L
E.Coli Confirmed	**363**	0	**0**	**0**	**0**	0	CFU_100ML
Field Free Chlorine	**365**	0	**0.34**	**0.51**	**0.71**		MG_P_L
Field Total Chlorine	**365**	0	**0.38**	**0.55**	**0.98**		MG_P_L
Fluoride	**10**	0	**50**	**319**	**380**	1,500	UG_P_L
Glyphosate	**6**	0	**0.005**	**0.01**	**0.005**	0.1	UG_P_L
Heptachlor	**4**	0	**0.005**	**0.01**	**0.005**		UG_P_L
Mercury Total	**10**	0	**0.04**	**0.04**	**0.06**	1	UGHG
Nitrate as NO3	**10**	0	**13.1**	**23.75**	**29.2**	50	MGNO_3
Nitrite as NO2	**10**	0	**0.003**	**0.01**	**0.008**	0.1	MGNO_2
Nitrogen Formula	**10**	0	**0.26**	**0.47**	**0.58**		MG_P_L
Sulphate	**10**	0	**37.3**	**38.36**	**39.4**	250	MGSO_4
Tetrachloroethene	**10**	0	**0.08**	**0.41**	**0.45**		UG_P_L
Tetrachloromethane	**10**	0	**0.07**	**0.15**	**0.16**	3	UG_P_L
Total Chlorethenes	**10**	0	**0.1**	**0.1**	**0.1**	10	MICROG_L
Total Coliforms (Confirmed)	**363**	0	**0**	**0**	**0**	0	CFU_100ML
Total Heptachlor Epoxide	**5**	0	**0**	**0**	**0**		UG_P_L
Total organic Carbon	**10**	0	**0.7**	**0.76**	**1.08**		MG_P_L
Total Oxidised Nitrogen	**10**	0	**13.1**	**23.75**	**29.2**		MG_P_L
Total Pesticides	**11**	0	**0**	**0**	**0**	0.5	UG_P_L
trans-Heptachlor epoxide	**5**	0	**0.007**	**0.01**	**0.007**		UG_P_L

Water Quality Summary Date Range: **01 Jul 2025 to 30 Jun 2026**

Treatment Works: **Oldford Treated**

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
Trichloroethene	**10**	0	**0.2**	**0.38**	**0.4**		UG_P_L
Turbidity - Indicator	**365**	0	**0.11**	**0.12**	**0.33**	1	NTU