Report Date:05-Aug-2026

PUBLIC REGISTER OF INFORMATION

Water Quality Summary Date Range: 01 Jul 2025 to 30 Jun 2026

Treatment Works: Tetbury Treated

Prescribed Concentration Values

Result Description	No. of Samples	No. of Failures	Min	Mean	Max	PCV	Units
1,2 Dichloroethane	**4**	0	**0.16**	**0.16**	**0.16**	3	UG_P_L
Benzene	**4**	0	**0.06**	**0.06**	**0.06**	1	UG_P_L
Boron Total	**4**	0	**67.8**	**71.78**	**76.1**	1,000	UG_P_L
Chloride as Cl	**4**	0	**21.2**	**21.55**	**22.5**	250	MGCL
Clostridia Perfringens Confirmed	**6**	0	**0**	**0**	**0**	0	CFU_100ML
Colony Count after 3 days @22C	**29**	0	**0**	**0.41**	**4**		CFU_1ML
Conductivity	**6**	0	**546**	**566.33**	**585**	2,500	US_P_CM
Cyanide Total as CN	**4**	0	**1.2**	**1.58**	**2.7**	50	UGCNL
E.Coli Confirmed	**28**	0	**0**	**0**	**0**	0	CFU_100ML
Field Free Chlorine	**28**	0	**0.51**	**0.58**	**0.65**		MG_P_L
Field Total Chlorine	**28**	0	**0.55**	**0.61**	**0.76**		MG_P_L
Fluoride	**4**	0	**220**	**230**	**240**	1,500	UG_P_L
Mercury Total	**4**	0	**0.022**	**0.04**	**0.04**	1	UGHG
Nitrate as NO3	**4**	0	**2.13**	**2.93**	**3.73**	50	MGNO_3
Nitrite as NO2	**4**	0	**0.003**	**0.01**	**0.008**	0.1	MGNO_2
Nitrogen Formula	**4**	0	**0**	**0**	**0**		MG_P_L
Sulphate	**4**	0	**55.2**	**59.2**	**62.7**	250	MGSO_4
Tetrachloroethene	**4**	0	**0.45**	**0.45**	**0.45**		UG_P_L
Tetrachloromethane	**4**	0	**0.16**	**0.16**	**0.16**	3	UG_P_L
Total Chlorethenes	**4**	0	**0.1**	**0.1**	**0.1**	10	MICROG_L
Total Coliforms (Confirmed)	**28**	0	**0**	**0**	**0**	0	CFU_100ML
Total organic Carbon	**4**	0	**0.7**	**0.7**	**0.7**		MG_P_L
Total Oxidised Nitrogen	**4**	0	**2.13**	**2.93**	**3.73**		MG_P_L
Trichloroethene	**4**	0	**0.4**	**0.4**	**0.4**		UG_P_L
Turbidity - Indicator	**28**	0	**0.11**	**0.12**	**0.29**	1	NTU